# Corrosion Protection for Fisher<sup>™</sup> FIELDVUE<sup>™</sup> Digital Valve Controllers

#### Standard Instrument Paint

Standard paints applied to instruments are formulated to withstand extreme exposures to corrosive atmospheres and are tested to confirm this benefit. Due to the excellent surface preparation and superior coatings applied to the prepared substrate, other more expensive coating systems are not necessary. The coatings used for instruments are baked-on finishes that will withstand the toughest environments and will keep on performing for years to come.

Comparisons of paints other than standard have shown no advantages in using other paints. Because of the potential impact on instrument performance, we are unable to apply coatings or paints other than our standard.

Figure 1. Fisher DVC6200 Digital Valve Controller with Standard Finish



**Table 1. Standard Instrument Paint Specifications** 

Technical Specifications—Standard Instrument Paint				
Surface Preparation	Clean, desmut, apply chromate conversion coating			
Coating Thickness	31 to 37 microns (1.25 to 1.5 mils)			
Standard Acceptance Test	Refer to the Standard Instrument Paint Panel Results in table 2			
Standard Color Specifications	Regal Gray—Munsell #8.4 B 3.47/0.60 Rosemount Blue—Federal Standard 595A- #25177			





## Standard Instrument Paint Test-Panel Results

Standardized flat-panel tests show the effect of common chemical exposures and physical attributes. Tests were performed on chromate conversion coated aluminum alloy panels. For more information about test conditions, procedures, and results, contact your Emerson sales office or Local Business Partner.

Table 2. Standard Instrument Paint Panel Results

	Table 2. Standard instrument rainer arter Results						
TEST	RESULT	TEST	RESULT	TEST	RESULT		
Hot and Cold Cycle	No effect	10% NH <sub>4</sub> OH	No effect	Mandrel Bend ASTM D522	PASSED		
10% HNO <sub>3</sub>	Slight loss of gloss to no effect	15% Xylene; 85% Mineral Spirits	Slightly lighter to no effect	Impact ASTM D2794	PASSED		
10% HCL	No effect	Unleaded Gasoline	No effect	Thread-locking Sealant Resin	PASSED		
3% H <sub>2</sub> SO <sub>4</sub>	No effect	Cross-Hatch Adhesion ASTM D3359	PASSED	Humidity, Ultraviolet, and Gravel Tests	PASSED		
10% NaOH	Slight loss of gloss to no effect	Pencil Hardness ASTM D3363	PASSED	Salt Cabinet ASTM B117	PASSED		

### DVC6200 Stainless Steel Alternative

As an alternative to painted instruments, the FIELDVUE DVC6200 digital valve controller can be furnished with a stainless steel module base, housing and an all-stainless mounting kit. The sealed terminal box isolates field wiring connections from other areas of the instrument and keeps water and harsh atmosphere away from electronic components. The DVC6200 stainless steel version eliminates all diecast aluminum parts, which greatly increases its resistance to the tough, corrosive environments found on offshore platforms, within chemical plants, and inside refinery processing units.

Figure 2. Fisher DVC6200 Digital Valve Controller Stainless Steel Version



#### Proprietary NCF (Non-Corroding Finish) Coating for Steel Fasteners

Standard steel fasteners such as bonnet bolting, actuator casing bolting, and steel fasteners for Fisher instruments have NCF (non-corroding finish) coating.

NCF coating was developed by Emerson Automation Solutions to greatly improve resistance to corrosion from acids, bases, salts, and many other chemicals and to follow the parameters listed in ASTM F1136 (Standard Specification for Zinc/Aluminum Corrosion Protective Coatings for Fasteners). NCF coating is a polymer-based coating consisting of multiple coats applied to all surfaces of bolts, studs, and nuts. (NCF coating is not used on steel bolting for temperatures over 427°C or 800°F). NCF coating is silver or gray in color and the finish is dull when compared with zinc plating.

The effectiveness of this proprietary coating designed specifically for the control valve market has been proven by actual testing on offshore platforms and accelerated salt-spray tests in the laboratory. NCF coated fasteners remain easily maintainable after offshore exposure. Original replacement NCF bolting is only available from Emerson Automation Solutions.

Figure 3. NCF-Coated Fasteners Exhibit Superior Performance in Accelerated Laboratory Tests




Table 3. NCF Coating Specifications

Technical Specifications—NCF Coating				
Surface Preparation	Pressure-retaining parts: Light blast			
	Non pressure-retaining parts: Light blast or zinc plating			
Coating Thickness	Approximately 0.025 mm (0.001 inches)			
Standard Acceptance Test	No red rust after 500 hours of ASTM B117 salt-spray test conducted on products after assembly with a pneumatic impact wrench			
Color	Light silver-gray			

Neither Emerson, Emerson Automation Solutions, nor any of their affiliated entities assumes responsibility for the selection, use or maintenance of any product. Responsibility for proper selection, use, and maintenance of any product remains solely with the purchaser and end user.

Fisher and FIELDVUE are marks owned by one of the companies in the Emerson Automation Solutions business unit of Emerson Electric Co. Emerson Automation Solutions, Emerson, and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Emerson Automation Solutions Marshalltown, Iowa 50158 USA Sorocaba, 18087 Brazil Cernay, 68700 France Dubai, United Arab Emirates Singapore 128461 Singapore

www.Fisher.com

